



WaterMark

Certificate of Conformity

Australian Certification Services Pty Ltd grants to the WaterMark Approved User:

BSP Enterprises Pty Ltd

Trading as BSP Enterprises Pty Ltd

the right to use the WaterMark as shown above in conjunction with the Certificate No. on product/s as identified in the WaterMark Schedule and as listed on the WaterMark database www.abcb.gov.au/Product-Certification/WaterMark-Certification-Scheme which have been shown to comply with the appropriate Applicable Specification referred to below and as amended from time to time. The WaterMark User is granted a licence to use the WaterMark subject to the rules governing the use of the WaterMark.

Product Type: Heated Water Systems – Tempering Valves
Product Use: Heated Water Supply
Brand: BSP/AVG
Certification Specification/s: AS 4032.2:2005 Water supply—Valves for the control of hot water supply temperatures Part 2: Tempering valves and end-of line temperature-actuated devices
Conditions or Limitations: To be installed in accordance with Plumbing Code of Australia (PCA)

Paul Greig
General Manager

Issue Date: 11th January 2021
Initial Issue Date: 11th April 2013
Expiry Date: 17th January 2024

Certificate No.: 23128

This Certificate is issued by a JAS-ANZ accredited certification body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate. The WaterMark Certification Scheme is a conformity assessment scheme based on ISO/IEC 17067. This Certificate may only be reproduced in its entirety





WaterMark Certification Schedule

The WaterMark User	BSP Enterprises Pty Ltd ABN: 32 080 649 627 21 Centella Circle Canningvale WA 6155 AUSTRALIA
Certificate Number	23128
Evaluation Specification/s:	AS 4032.2:2005 Water supply—Valves for the control of hot water supply temperatures Part 2: Tempering valves and end-of line temperature-actuated devices

Product Listing

Model Identification	Model Name	Brand Name	Product Description
TVA25HF	HI-FLO	BSP/AVG	DN25 Tempering Valve Temperature Adjustable 35°C to 50°C Integral Non Return Valves and Strainers Factory Preset 50°C
TVA25-20HF	HI-FLO	BSP/AVG	DN25/DN20 Tempering Valve Temperature Adjustable 35°C to 50°C Integral Non Return Valves and Strainers Factory Preset 50°C
TVA20HF	HI-FLO	BSP/AVG	DN20 Tempering Valve. Temperature Adjustable 35°C to 50°C Integral Non Return Valves and Strainers Factory Preset 50°C
TVA20ABV-25HF	HI-FLO	BSP/AVG	DN20/DN25 Tempering Valve Temperature Adjustable 35°C to 50°C Integral Non-return Valves and Strainers Isolating Valves Factory Preset 50°C
ecotherm iPC commercial	ecotherm iPC commercial	BSP/AVG	DN20 Tempering Valve Temperature Adjustable 35°C to 50°C Pressure Limiting Function (350/500kPa) Integral Non-return Valves and Strainers Isolating Valves Factory Preset 40°C Loose Nut Connection Ends with optional Telescopic Joiner

